

SECTION 1

New York State Department of Environmental Conservation
Division of Water

2W

Report Noncompliance Event

To: DEC Water Contact: Val Murakami DEC Region: 7
 Report Type: 5 day Permit Violation Order Violation Anticipated Noncompliance X Bypass/Overflow Other

SECTION 2

SPDES #: NY-- 0025106 Facility: Westside Wastewater Treatment Plant
 Date of noncompliance: 2/6/19 Location (Outfall, Treatment Unit, or Pump Station): Outfall WWTP-SSO #004
 Description of noncompliance(s) and cause(s): Bypass of sanitary sewer wastewater occurred through unpermitted Outfall #004
High flows caused by rain and snow melt over plant capacity.

Has event ceased? (Yes) (No) If so, when? 2/6/19 Was event due to plant upset? (Yes) (No) SPDES limits violation (Yes) (No)
 Start date, time of event: 2/6/19 4:05 (AM) (PM) End date, time of event: 2/6/19 10:40 (AM) (PM)
 Date, time oral notification made to DEC? 2/6/19 5:20 (AM) (PM) DEC Official contacted: Val Murakami
 Immediate corrective actions: All wet weather procedures were implemented immediately

Preventive (long term) corrective actions: Ongoing separation projects of the Westside Collection system are on schedule as per consent decree.

SECTION 3

Complete this section if event was a bypass:

Bypass amount: 92,000 gals Was prior DEC authorization received for this event? (Yes) (No)
 DEC Official contacted: _____ Date of DEC approval _____

Describe event in "Description of noncompliance and cause" area in Section 2. Detail the start and end dates and times in Section 2 also.

Forms by EnviroWin (312-244-1900)

SECTION 4

Facility Representative John McGrath Title: Chief Operator Date: 2/6/19

Phone #: 315 342-3777 Fax #: 315 342-8233

3506-101 (12/93)

Signature: 