

SECTION 1

New York State Department of Environmental Conservation
Division of Water

12

Report Noncompliance Event

To: DEC Water Contact: Val Murakami DEC Region: 7
Report Type: 5 day Permit Violation Order Violation Anticipated Noncompliance X Bypass/Overflow Other

SECTION 2

SPDES #: NY-- 0029106 Facility: Westside Wastewater Treatment Plant
Date of noncompliance: 6/5/16 Location (Outfall, Treatment Unit, or Pump Station): Outfall WWTP-SSO #004
Description of noncompliance(s) and cause(s): Bypass of sanitary sewer wastewater occurred through an unpermitted outfall located at the Westside Wastewater Treatment Facility. High flows caused by sudden heavy rain fall.
Over plant design flow of 12 mgd.

Has event ceased? (Yes)(No) If so, when? 6/5/16 Was event due to plant upset? (Yes) (No) SPDES limits violation (Yes) (No)
Start date, time of event: 6/5/16 1:07 (AM)(PM) End date, time of event: 6/5/16 1:39 (AM)(PM)
Date, time oral notification made to DEC? 6/5/16 2:22 (AM)(PM) DEC Official contacted: Val Murakami
Immediate corrective actions: Influent gate automatically adjusted to bring flows within design capacity.
We put an empty Secondary Tank on-line to help the plant deal with increased flow.

Preventive (long term) corrective actions: Ongoing separation projects of the Westside Collection system are on schedule as per consent decree.

SECTION 3

Complete this section if event was a bypass:

Bypass amount: 15,000 Was prior DEC authorization received for this event? (Yes)(No)
DEC Official contacted: Date of DEC approval:

Describe event in "Description of noncompliance and cause" area in Section 2. Detail the start and end dates and times in Section 2 also.

Forms by EnviroWin (312-244-1900)

SECTION 4

Facility Representative Gary T. Hallinan Title: Superintendent Date: 6/6/16

Phone #: 315 342-3777 Fax #: 315 342-8233

3506-101 (12/93)

Signature: _____