

SECTION 1

New York State Department of Environmental Conservation
Division of Water

2W

Report Noncompliance Event

To: DEC Water Contact: Val Murakami

Report Type: 5 day Permit Violation Order Violation Anticipated Noncompliance X Bypass/Overflow Other

DEC Region: 7

SECTION 2

SPDES #: NY-- 0029106

Facility: Westside Wastewater Treatment Plant

Date of noncompliance 4/30/20

Location (Outfall, Treatment Unit, or Pump Station): Outfall WWTP-SSO #004

Description of noncompliance(s) and cause(s):
#004 due to high flows caused by rain.

Bypass of sanitary sewer wastewater occurred through unpermitted Outfall

Has event ceased? (Yes)(No) If so, when? 5/1/20 Was event due to plant upset? (Yes) (No) SPDES limits violation (Yes) (No)
Start date, time of event: 4/30/20 5:25 (AM)(PM) End date, time of event: 5/1/20 5:00 (AM)(PM)
Date, time oral notification made to DEC? 4/30/20 7:30 (AM)(PM) DEC Official contacted: Val Murakami
Immediate corrective actions: All wet weather procedures have been implemented.

Preventive (long term) corrective actions: Ongoing separation projects of the Westside Collection system are on schedule as per consent decree.

SECTION 3

Complete this section if event was a bypass:

Bypass amount: 435,000 gals Was prior DEC authorization received for this event? (Yes)(No)
DEC Official contacted Date of DEC approval

Describe event in "Description of noncompliance and cause" area in Section 2. Detail the start and end dates and times in Section 2 also.

SECTION 4

Forms by EnviroWin (312-244-1900)

Facility Representative John McGrath

Title: Chief Operator

Date: 5/4/20

Phone #: 315 342-3777

Fax #: 315 342-8233

3506-101 (12/93)

Signature:

John W. McGrath